

BIDS AND AWARDS COMMITTEE FOR FREE WI-FI INTERENET ACCESS IN PUBLIC PLACES PROJECT (BAC4FREEWIFI)

Supplemental Bid Bulletin No. 1

Supply, Delivery, Installation, Testing and Acceptance of One Lot Brand New Power Generators for the Ten (10) Point of Presence Sites

Bid Reference No. BAC4FREEWIFI-2016-04-006 (REBID)

After considering the queries, clarifications, recommendations and suggestions, the BAC4FREEWIFI hereby decides to include, revise, amend, delete and/or adapt the following provisions:

QUERY	BAC4FREEWIFI'S RESPONSE
In Section VII. Specifications, Item 4.12. Certification. "submit certification that their Offered equipment is used in (1) USA or Canada (2) Europe (any country in Europe); and Japancertification from our Supplier/Principal that they have supplied to the countries noted above? Certification of which them, our supplier/principal composed and signed by their authorized personnel?	No. Just accomplish Annex XI form, page 110 of the bid documents. Please note that the submitted Certification will be validated/checked during post qualification process.



QUERY	BAC4FREEWIFI'S RESPONSE			
Can you provide us	Each site will have different installation set-up. Please coordinate with the			
a simple Plan of the				
installation for each	Cluster	Location	Contact Person	Contact No.
site, prominently	Luzon Cluster 2	Dau	Engr Pablito De La	09328562958/
showing the			Pena/	09326223432
generator place			Engr. Ric Juangco	
with the ATS, and	Luzon Cluster 2	Dagupan	Engr Pablito De La	09328562958/
with the main			Pena/	09228409497
breaker of the			Engr. Rillera	
facility it will serve.	Luzon Cluster 3	Batangas	Engr. Bassanio	09228041859
			Torio	
	Luzon Cluster 3	Puerto	Mr. Victor Enciso/	09088995978/
		Princesa	Engr. Bassanio	09228041859
			Torio	
	Luzon Cluster 3	Legaspi	Engr. Amador	09175071327/
			Cabredo/	09228041859
			Engr. Bassanio	
			Torio	
	Luzon Cluster 3	Lipa	Engr. Bassanio	09228041859
	\ \tau_{i} \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \		Torio	00470240502
	Visayas Cluster	Tacloban	Engr Boy Yobia	09173218583
	Visayas Cluster	Calbayog	Engr. Badrina	09166316302
	2	Calbayog	Liigi. Dauiilia	09100310302
	Mindanao	Zamboanga	Guilbert Simene	09186356416
	Cluster 1	Lambourigu		
	Mindanao			
	Cluster 1	Pagadian	Engr. Noel Flores	09491825393
Further are the				
•	Yes.			
Further, are the main breaker ampere rating of each site is the same ampere rating of the transfer switch?	Yes.			



QUERY	BAC4FREEWIFI'S RESPONSE
There is no mention of the materials general information to be used, such as wire size, Wire enclosures (conduit or PVC), ATS type (breaker or change over), terminal lugs type. We want clarification on this as in the terms of reference, each site has its own authorized person to accept the installation, they may have different disposition on the materials used, Even if is technically complying, but not on brand or type as the accepting person so desires.	Wire Size – 30mm ² Wire Enclosures - IMC Conduit ATS Type – Change Over Terminal Lugs type – Grounding Type
Further, may we request a delivery extension of from 90 days to 120 days from reckoning Receipt of Award.	Request is denied

ORIGINAL PROVISION	AMENDED PROVISION	
Section VII. Techn	nical Specifications	
 4.9 Complete Standard Accessories: Industrial Batteries Fuel Base Tank Industrial-Type Exhaust Silencer/Muffler Auto-crank/Auto Start Module In-house and hands-on training & orientation for proper Gen Set operation and basic maintenance/troubleshooting One (1) Set of Operation and Maintenance Manuals, including Parts Manuals 	 4.9 Complete Standard Accessories: Industrial Batteries Trickle Battery Charger Fuel Base Tank Industrial-Type Exhaust Silencer/Muffler Auto-crank/Auto Start Module In-house and hands-on training & orientation for proper Gen Set operation and basic maintenance/troubleshooting One (1) Set of Operation and Maintenance Manuals, including Parts Manuals 	

All terms, conditions and instructions to bidders specified in the Bidding Documents inconsistent with this Bid Bulletin are hereby superseded and modified accordingly.



Please use the following forms attached in this Supplemental Bid Bulletin:

Revised Technical Specifications as of 10 May 2016

For information and guidance of all concerned.

Issued this 10th day of May 2016.

MARIA LOURDES P. AQUILIZAN

Vice Chairperson, BAC4FREEWIFI



Revised Technical Specifications as of 10 May 2016

INSTRUCTION TO THE SUPPLIER: Indicate "COMPLY" per line number under Bidder's Statement of Compliance if Bidder can meet the technical specifications and project requirements. DO NOT LEAVE ANY BLANK. A "YES" or "NO" ENTRY WILL NOT BE ACCEPTED. FAILURE TO CONFORM WILL RESULT IN A RATING OF "FAILED".

SUPPLY, DELIVERY, INSTALLATION, TESTING AND ACCEPTANCE OF ONE LOT OF BRAND NEW POWER GENERATORS FOR THE TEN (10) POINT OF PRESENCE SITES

ITEM	MINIMUM SPECIFICATIONS	STATEMENT OF COMPLIANCE		
1.	This tender is for the Supply, Delivery, Installation, Testing and Acceptance of brand new Generator Set with Automatic Transfer Switch (ATS) and other Complete Standard Accessories, one for each of the ten (10) Point of Presence Sites (PoPs).			
2.	The total of the Approved Budgetary Cost (ABC) for this tender is NINE MILLION FIVE HUNDRED THOUSAND PESOS (PhP9,500,000.00).			
3.	The Supply, Delivery, Installation, Testing and Acceptance of all Generator Sets shall be made within NINETY (90) days from receipt of Notice to Proceed.			
4.1.	Minimum Capacity: 45 kVA, 125 Amperes ATS			
4.2.	Type: Diesel feed, silent type, weather proof			
4.3.	Voltage: 230-240 Volts, AC			
4.4.	Enclosure (Canopy): Original Equipment Manufacturer (OEM)			
4.5.	Frequency: 60 Hz			
4.6.	Power Factor: 80%			
4.7.	Revolution per Minute (RPM): 1,800			
4.8.	Phase: 3			
4.9.	 Complete Standard Accessories: Industrial Batteries Trickle Battery Charger Fuel Base Tank Industrial-Type Exhaust Silencer/Muffler Auto-crank/Auto Start Module In-house and hands-on training & orientation for proper Gen Set operation and basic maintenance/troubleshooting One (1) Set of Operation and Maintenance Manuals, including Parts Manuals 			



	Bidder/suppli used in (1) U ope); and (3 s:	er must nited Sta) Japan	submit ce ates of An	ertification t nerica or Ca	hat their offered anada; (2) Europe (Any Address DAU Homesite, 2-A DAU Expressway, DAU, Mabalacat, Pampanga, Dau, Mabalakat, Pampanga	
Certification: Bequipment is used to country in Europelivery Points Coordinates a PoP Name Dau PoP Dagupan	Bidder/suppliused in (1) Uope); and (3) s: are given with Locality	er must Inited Sta) Japan Chout gua Provi nce Pampan ga	submit ce ates of An arantee o *Lat	ertification to nerica or Ca f accuracy *Long	Address DAU Homesite, 2-A DAU Expressway, DAU, Mabalacat, Pampanga, Dau, Mabalakat,	
PoP Name Dau PoP Dagupan	Locality Dau	Provi nce Pampan ga	*Lat	*Long	DAU Homesite, 2-A DAU Expressway, DAU, Mabalacat, Pampanga, Dau, Mabalakat,	
Dau PoP Dagupan	Dau	Pampan ga			DAU Homesite, 2-A DAU Expressway, DAU, Mabalacat, Pampanga, Dau, Mabalakat,	
Dagupan		ga	15.17977	120.591238	Expressway, DAU, Mabalacat, Pampanga, Dau, Mabalakat,	
	Dagupan City	Pangasi			i ampanya	
		nan	16.04399	120.334307	Poblacion Oeste, A. B. Fernandez West, Dagupan City, Pangasinan	
Batangas City PoP	Batangas City	Batanga s	13.76543	121.063118	Capitol Site, Batangas City, Batangas	
Puerto Princesa PoP	Puerto Princesa City	Palawan	9.737894	118.734449	Burgos Street, Puerto Princesa City, Palawan	
Legaspi City PoP	Legaspi City	Albay	13.14473	123.753452	Post-Telecom Bldg., Lapu-Lapu Street, Legaspi City, Albay	
Lipa City PoP	Lipa City	Batanga s	13.94113	121.15449 7	B. Morada Avenue, Lipa City	
Tacloban City PoP	Tacloban City	Leyte	11.24506	125.004744	Post-Telecom Bldg., , Port Area, Tacloban City, Leyte	
Calbayog City PoP	Calbayog City	Western Samar	12.07264	124.596884	Calbayog City, Western Samar	
Zamboang a City PoP	Zamboanga City	Zamboa nga Del Sur	6.902776	122.07341	Port Area, Brgy Zone IV, 7000 Zamboanga City, Port Area, Zambonga City, Zamboanga del Sur	
Pagadian City PoP	Pagadian City	Zamboa nga Del Sur	7.828975	123.438448	Corner Urro and Alano Streets, , Pagadian City, Zamboanga del Norte	
	Princesa PoP Legaspi City PoP Lipa City PoP Tacloban City PoP Calbayog City PoP Zamboang a City PoP Pagadian City PoP	Princesa PoP Legaspi City PoP Lipa City PoP Tacloban City PoP Calbayog City PoP Zamboang a City PoP Pagadian City PoP Tagadian City PoP Pagadian City PoP Tagadian City PoP Pagadian City PoP Tagadian City PoP Pagadian City PoP Tacloban City Calbayog City City Pagadian City PoP Tacloban City Calbayog City Zamboanga City Pagadian City PoP Tacloban City Calbayog City Pagadian City PoP Tacloban City City Dayment Shall be made up	Princesa PoP Princesa PoP Princesa City Princesa City Batanga S Sur Pagadian City PoP Pagadian City Princesa City Batanga S Western Samar Zamboa nga Del Sur Princesa City Pagadian City PoP Pagadian City Princesa City Pagadian City Pagadian City Princesa City Princesa City Pagadian City Princesa	Princesa PoP Legaspi City PoP Lipa City Leyte 11.24506 Leyte 12.07264 Leyte Leyte Pagadian City PoP Lipa City PoP Calbayog Calbayog City City Leyte Leyte 12.07264 Leyte Leyte Leyte 12.07264 Leyte Leyte 12.07264 Leyte Leyte Leyte Leyte Leyte 12.07264 Leyte Le	Princesa PoP Princesa City Palawan 9.737894 118.734449 Legaspi City PoP Legaspi City Albay 13.14473 123.753452 Lipa City PoP Lipa City PoP Tacloban City City PoP Tacloban City City PoP Calbayog City PoP City Zamboang a City PoP Zamboang a City PoP Pagadian City PoP Pagadian City PoP Pagadian City PoP City Camboa City Camb	Princesa PoP Princesa City Palawan Palawan Princesa City Princesa City PoP Princesa City PoP Princesa City PoP Princesa City PoP Post-Telecom Bldg., Lapu-Lapu Street, Legaspi City, Albay PoP Post-Telecom Bldg., Lapu-Lapu Street, Legaspi City, Albay PoP Post-Telecom Bldg., Lapu-Lapu Street, Legaspi City, Albay PoP Post-Telecom Bldg., Post-Telecom Bldg., Post-Telecom Bldg., Post-Telecom Bldg., Port Area, Tacloban City PoP Port Area, Tacloban City, Leyte PoP



7.1.	All Generator Sets, including its standard accessories, must undergo the "Test Procedures Integrated Power System", supervised by FOO Cluster acceptance representatives.	
7.2.	Procedures are as follows, showing actual results and to mark if results did pass or fail	
7.2.1.	 For Diesel Generator Manual Start Engine should start and run continuously until manually stopped without any faults or alarms on the control panel. Record all reading in control panel 4 minutes Run test (without load) The engine should run continuously for 4 minutes until manually stopped without any faults or alarms on the control panel. Record all reading in control panel 2 hours Run test (with load) The engine should run continuously from 2 hours until manually stopped 	
	without any faults or alarms on the control panel b. Test load should be provided by bidder. 4. Battery Charging System a. Battery voltage reading must be above normal battery level 5. Oil and Liquid Coolant levels a. Level should be within the recommended level by manufacturer	
7.2.2.	 For ATS Power outage transfer test a. Must be able to show that the Genset automatically starts and power supply of the whole electrical system is transferred to the genset. Restored Power transfer test a. Must be able to show that power supply for the whole electrical system is transferred from the Genset to the original source and genset is automatically turned off subsequently 	
7.2.3.	 Full System Test Simulation of power outage a. Must be able to show that the Genset automatically starts and power supply of the whole electrical system is transferred to the genset within the time set. Simulation of restored power a. Must be able to show that power supply for the whole electrical system is transferred from the genset to the original source and genset is automatically turned off subsequently b. Must be able to show that normal power supply is restored 	



8.1.	Franchise Requirements. Non-franchise holders may participate in this tender but without prejudice to other legal requirements, particularly with respect to the provisioning of commercial services outside the PROJECT.				
8.2.	Installations Costs and Other One Time Charges (OTC). No OTCs shall be allowed.				
8.3.	Taxes & Other Fees. All propose charges and other one-time co	sals shall be inclusive of all taxes, installati sts, and other fees.	ion		
	charges and other one time co	ses, and other rees.			
	Name of Company	Signature Over Printed Name Of Authorized Representative	Date		



ICT OFFICE BAC4FREEWIFI

REVISED CHECKLIST OF REQUIREMENTS FOR BIDDERS AS OF 10 MAY 2016

Name of Company:

Project : SUPPLY, DELIVERY, INSTALLATION, TESTING AND

ACCEPTANCE OF ONE LOT OF BRAND NEW POWER

GENERATORS FOR THE TEN (10) POINT OF

PRESENCE SITES

Bid Ref No. : BAC4FREEWIFI-2016-04-006 (REBID)

APPROVED BUDGET FOR THE CONTRACT: Php9,500,000.00

APPRO	PROVED BUDGET FOR THE CONTRACT : Php9,500,000.00					
Ref. No.	Particulars					
ENVELOPE 1: ELIGIBILITY AND TECHNICAL DOCUMENTS						
	BILITY DOCUMENTS					
	S "A" DOCUMENTS					
12.1	(a.1.) ELIGIBILITY DOCUMENTS					
	i. Registration certificate from the Securities and Exchange Commission (SEC), Department of Trade and Industry (DTI) for sole proprietorship, or Cooperative Development Authority (CDA) for cooperatives					
	ii. Business/Mayor's permit for 2016 issued by the city or municipality where the principal place of business of the prospective bidder is located					
	iii. Valid and Current Tax Clearance per Executive Order 398, Series of 2005, as finally reviewed and approved by the BIR.					
	iv. Statement of all its Ongoing (including awarded contract/s not yet started, if any) within the last three (3) Years, (Annex I)					
	v. Statement of Completed Single Largest Contract from January 2010 up to the day before the deadline for the submission bids of similar in nature equivalent to at least fifty percent (50%) of the ABC. Annex I-A					
	vi. Copy of 2015 or 2014 Annual Income Tax Return submitted through BIR's Electronic Filing and Payment System (EFPS) together with the following Audited Financial Statements for 2015 and 2014 or 2014 and 2013 (in comparative form or separate reports): a) Copy of Independent Auditor's Report;					
	b) Balance Sheet (Statement of Financial Position);					



- c) Income Statement (Statement of Comprehensive Income); Each of the above statements must have stamped **"received"** by the Bureau of Internal Revenue (BIR) or its duly accredited and authorized institutions
- vii. Duly signed Net Financial Contracting Capacity Computation (NFCC) per **Annex II**, in accordance with ITB Clause 5.5

 NFCC = [(Current Assets minus Current Liabilities) (K)] minus the value of all outstanding or uncompleted portions of the projects under ongoing contracts, including awarded contracts yet to be started coinciding with the contract to be bid.

Where:

K: 10 for a contract duration of one year or less, 15 for a contract duration of more than one year up to two years, and 20 for a contract duration of more than two years.

Notes:

- 1. The values of the bidder's current assets and current liabilities shall be based on the data submitted to BIR through its Electronic Filing and Payment System.
- 2. Value of all outstanding or uncompleted contracts refers those listed in Annex-I.
- 3. The detailed computation using the required formula must be shown as provided above.

CLASS "B" DOCUMENTS (FOR JOINT VENTURE)

- i. For Joint Ventures, Bidder to submit either:
 - 1. Copy of the JOINT VENTURE AGREEMENT (JVA) in case the joint venture is already in existence, or
 - 2. Copy of Protocol / Undertaking of Agreement to Enter into Joint Venture signed by all the potential join venture partners stating that they will enter into and abide by the provisions of the JVA in the instance that the bid is successful. (Annex III)

The JVA or the Protocol/Undertaking of Agreement to
Enter into Joint Venture (Annex III) must include/specify
the company/partner and the name of the office
designated as authorized representative of the Joint
Venture.



For Joint Venture,	the following	documents	must likewise
be submitted:			

For Joint Venture **Between Two (2) Local Companies**, each partner should submit:

- Registration Certificate from the Securities and Exchange Commission (SEC) for corporations, Department of Trade and Industry (DTI) for sole proprietorship, or Cooperative Development Authority (CDA) for cooperatives;
- 2. Business/Mayor's permit for 2016 issued by the city or municipality where the principal place of business of the prospective bidder is located;
- 3. Valid and Current Tax Clearance per Executive Order 398, Series of 2005, as finally reviewed and approved by the BIR.

For item (iv) to (vii) of the required eligibility documents, submission by any of the Joint Venture partner constitutes compliance.

TECHNICAL DOCUMENTS

Bid security shall be issued in favor of the INFORMATION AND COMMUNICATIONS TECHNOLOGY OFFICE (ICT Office) valid at least one hundred twenty (120) days after date of bid opening in any of the following forms:

- a) BID SECURING DECLARATION per **Annex IV**; or
- b) Cashier's / Manager's Check equivalent to at least 2% of ABC issued by a Local or Universal or Local Commercial Bank.

12.1	
(b)(i)	

Description	Qty	ICT Office ABC Total Price	Bid Security: Cash, Cashier's / Manager's Check, (2%) (P)
Supply, Delivery, Installation, Testing And Acceptance of One Lot Of Brand New Power Generators For The Ten (10) Point Of Presence Sites	1 Lot	P 9,500,000.00	P 190,000.00

12.1 (b)(ii)

Duly signed and completed Technical Bid Form. Bidder must use, accomplish and submit the Technical Bid Form hereto attached as **Annex V**.



12.1 (b)(x)	Proof of Authority of the Bidder's authoriz a) FOR SOLE PROPRIETORSHIP (IF A REPRESENTATIVE): Duly notarized Special Power of Atto b) FOR CORPORATIONS, COOPERATIONS, COOPERATIONS (COOPERATIONS) THE JOINT VENTURE: Duly notarized Secretary's Certificate designated representative/s. IN THE CASE OF UNINCORPORATED member shall submit a separate Special Formula Secretary's Certificate evidencing the authorized secretary's Certificate evidencing the authorized secretary's.	rney TIVE O evidence JOINT	PR THE MEMBERS OF cing the authority of the TVENTURE: Each of Attorney and/or	
12.1 (b)(xi) Section VI. Section VII.	Omnibus Sworn Statements using the for a) Authority of the designated represen b) Non-inclusion of blacklist or under succ) Authenticity of Submitted Documents d) Authority to validate Submitted Documents d) Disclosure of Relations f) Compliance with existing labor laws a g) Bidder's Responsibilities h) Did not pay any form of consideration i) Company Official Contact Reference Schedule of Requirements (Section VI) Revised Technical Specifications as of 10	tative ispension ments and stain	on status ndards	
13.1 (a)	Completed and signed Financial Bid Form and submit Financial Bid Form hereto attained and Submit Financial Bid For		, ,	



	The ABC is inclusive of VAT. Any proposal with a financial component exceeding the ABC shall not be accepted. Further, the sum of bid for each item indicated in the Detailed Financial Breakdown per Annex VII-A must be equal to the signed and submitted Financial Bid Form per Annex VII.	
	Detailed Financial Breakdown per Annex VII-A	
15.4 (a)(i) & 15.4 (b)(ii)	Completed "For Goods Offered from Abroad" and/or "For Goods Offered From Within the Philippine" Forms per Annex VIII-A and Annex VIII-B, whichever is applicable.	
13.1 (b)	If the Bidder claims preference as a Domestic Bidder or Domestic Entity, a Certification from the DTI, SEC or CDA to be enclosed pursuant to the Revised IRR of R.A. 9184.	
NOTE:	In case of inconsistency between the Checklist of Requirements for Bidders and the provisions in the Instruction to Bidders/Bid Data Sheet, the Instruction to Bidders/Bid Data Sheet shall prevail	